

Hugh "Bubba" Hodge, Mayor
Griffin Lotson, Mayor Pro-Tempore
Augustus Skeen, Councilmember
Barbara Shaw, Councilmember
Marcy H. Goodyear, Councilmember



Tim Sweezey, MPA, City Manager
Priscilla Taylor, City Clerk
Richard Braun, City Attorney

City of Darien WWTP Maintenance/Upgrades -- RFP

Addendum No. 1

March 14, 2019

Change to RFP:

On Page 3...

- Sludge pump
 - Assess sludge removal process
 - Assess sludge pumps
 - Repair or replace sludge pumps
 - Assess wall structure and repair as necessary

This statement should NOT be under the heading "Sludge Pump", but under heading "Headworks"

- Assess wall structure and repair as necessary

On Page 7...

The Bid Bond Requirement has been waived. **Bid Bond is NOT required to be submitted with proposal.** Performance Bond will still be required of the successful proposer.

Questions and Answers:

Q1: Will Roberts Civil Engineering be performing engineering design support for contractors?

A1: No, Roberts Civil Engineering will not be providing engineering support. If additional engineering design is required, the proposing contractor will need to include engineering in their budget.

Q2: In recent years, have they had any sort of permitting or compliance issues from EPD. If they have, what were they?

A2: Yes. In Jan. of 2019, Max Loading and Concentration for Ammonia and Max Monthly Ammonia Concentration. In Dec. of 2018, Max Ammonia Concentration Week and Monthly Minimum Percentage of Removal of TSS.

Attachments to this addendum:

- Copy of Permit
- Random Sampling Results
- Copy of Original Design Plans
- Sign-In Sheets from Site Visits